

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 8160-2064:0026 Page 1 of 1

CATEGORY: 8160 -- UNDER EAVE FOR WILDLAND URBAN INTERFACE (W.U.I)

LISTEE: Nusku Partners LLC 4501 Brickell Privado Street, Ontario, CA 91761
Contact: Tim Hummel (909) 591-4841 Fax (909) 591-4818
Email: tim@wehardenhomes.com

DESIGN: "Nusku Fireblocker" Clear Fire Retardant Fingerjoint Redwood ceiling cladding products to include Tongue & Groove and Shiplap minimum dimension 1x4 (nominal) installed over standard 7/16" oriented strand board (OSB), plywood or gypsum. Refer to manufacturer's installation instructions and product data sheet.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee name. Model number, rating and SFM label.

APPROVAL: Listed as under eave materials for use in the Wildland Urban Interface areas. Refer to manufacturer's Installation Manual for details.

NOTE: Test Protocol SFM 12-7A-3

10-22-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO,, M.E., F.P.E.**
Fire Engineering Division